

2014 Consumer Confidence Report

Water System Name: CITY OF RIO VISTA

Report Date:

May 2015

We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 - December 31, 2014.

Este informe contiene informacion muy importante sobre su agua potable. Traduzcalo 6 hable con alguien que lo entienda bien.

Type of water source(s) in use: According to CDPH records, Wells 07, 09, and 11, are Groundwater. This Assessment was done using the Default Groundwater System Method. This info is not available for Wells 13, 14, 15, and Booster Station, as they do not have a completed assessment on file. Please see the Drinking Water Source Assessment Information section located at the end of this report for more details.

Your water comes from 7 source(s): Booster Station, Well 07, Well 09, Well 11, Well 13, Well 14 and Well 15

Total gallons pumped: 814 million gallons

Opportunities for public participation in decisions that affect drinking water quality: Regularly-scheduled water board or city/county council meetings are held at Rio Vista Fire Station every 2nd Tuesday of each month at 6:30pm.

For more information about this report, or any questions relating to your drinking water, please call (707) 374-6451, Ext. 1116 and ask for Dave Melilli or visit our website at www.rio-vista-ca.com.

TERMS USED IN THIS REPORT

Maximum Contaminant Level (MCL): The highest level of contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (USEPA).

Public Health Goal (PHG): The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

The sources of drinking water: (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Primary Drinking Water Standards (PDWS): MCLs and MRDLs for the contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.

Secondary Drinking Water Standards (SDWS): MCLs for the contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.

Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water.

Regulatory Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

ND: not detectable at testing limit

ppm: parts per million or milligrams per liter (mg/L) **ppb:**

parts per billion or micrograms per liter ($\mu\text{g/L}$) **pCi/L:**

picocuries per liter (a measure of radiation)

Contaminants that may be present in source water include:

- *Microbial contaminants*, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- *Inorganic contaminants*, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- *Pesticides and herbicides*, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- *Organic chemical contaminants*, including synthetic and volatile organic chemicals, that are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- *Radioactive contaminants*, that can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, the USEPA and the California Department of Public Health (Department) prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. Department regulations also establish limits for contaminants in bottled water that provide the same protection for public health.

Tables 1, 2, 3, 4, 5 and 6 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The Department allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old.

Table 1- SAMPLING RESULTS SHOWING THE DETECTION OF LEAD AND COPPER						
Lead and Copper (complete if lead or copper detected in last sample set)	Sample Date	90th percentile level detected	No. Sites Exceeding AL	AL	PHG	Typical Sources of Contaminant
Copper (ppm)	20 (2013)	0.05	0	1.3	.3	Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives

Table 2 - SAMPLING RESULTS FOR SODIUM AND HARDNESS						
Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Sources of Contaminant
Sodium (ppm)	(2013 - 2014)	143	118 - 155	none	none	Salt present in the water and is generally naturally occurring
Hardness (ppm)	(2013 - 2014)	77.2	65.4 - 101	none	none	Sum of polyvalent cations present in the water, generally magnesium and calcium, and are usually naturally occurring

NOTE: A hardness of 60 is considered slightly hard and a hardness of 120 is considered moderately hard. There is no convincing evidence that water hardness causes adverse health effects. It is primarily a nuisance problem resulting in difficulty in cleaning and laundering tasks, and decreased efficiency of water heaters.

Any violation of MCL, AL or MRDL is highlighted. Additional information regarding the violation is provided later in this report.

Table 3 - DETECTION OF CONTAMINANTS			WITH A PRIMARY		DRINKING WATER STANDARD	
Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Sources of Contaminant
Arsenic (ppb)	(2014)	9	5 - II	10	n/a	Erosion of natural deposits; runoff from orchards, glass and electronics production wastes
Fluoride (ppm)	(2013 - 2014)	0.4	0.2 - 0.5	2	1	Erosion of natural deposits; water additive that promotes strong teeth; discharge from fertilizer and aluminum factories.

Hexavalent Chromium (ppb)	(2014)	1.39	ND - 2.99	10	0.02	Discharge from electroplating factories, leather tanneries, wood preservation, chemical synthesis, refractory production, and textile manufacturing facilities; erosion of natural deposits.
Nitrate (ppm)	(2006 - 2014)	13.2	4.5 - 32.9	45	45	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits
Nitrate + Nitrite as N (pp ^m)	(2013)	2.6	2.0 - 3.2	10	10	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits
Selenium (ppb)	(2013)	5	ND - 10	50	30	Discharge from petroleum, glass, and metal refineries; erosion of natural deposits; discharge from mines and chemical manufacturers; runoff from livestock lots(feed additive)
Gross Alpha (pCi/L)	(2010)	1.53	1.31 - 1.74	15	(0)	Erosion of natural deposits.
Total Radium 228 (pCi/L)	(2007 - 2010)	ND	ND - 0.859	5	n/a	Erosion of natural deposits

Table 4 - DETECTION OF CONTAMINANTS WITH A SECONDARY DRINKING WATER STANDARD

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Sources of Contaminant
Chloride (ppm)	(2013 - 2014)	76	68 - 82	500	n/a	Runoff/leaching from natural deposits; seawater influence
Iron (ppb)	(2013 - 2014)	643	ND - 2230	300	n/a	Leaching from natural deposits;Industrial wastes
Manganese (ppb)	(2013 - 2014)	460	ND - 1580	50	n/a	Leaching from natural deposits
Specific Conductance (umhos/cm)	(2013 - 2014)	766	500 - 918	1600	n/a	Substances that form ions when in water; seawater influence
Sulfate (ppm)	(2013 - 2014)	38	18 - 57	500	n/a	Runoff/leaching from natural deposits; industrial wastes
Total Dissolved Solids (ppm)	(2013 - 2014)	451	270 - 520	1000	n/a	Runoff/leaching from natural deposits
Turbidity (NTU)	(2013)	0.4	ND - 0.7	5	n/a	Soil runoff

Any violation of MCL, AL or MRDL is highlighted. Additional information regarding the violation is provided later in this report.

Table 5 - DETECTION OF UNREGULATED CONTAMINANTS

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	Notification Level	Typical Sources of Contaminant
Boron (ppm)	(2013 - 2014)	1	0.6 - 1.4	1	The babies of some pregnant women who drink water containing boron in excess of the notification level may have an increased risk of developmental effects, based on studies in laboratory animals.
Vanadium (ppm)	(2013)	0.01	ND - 0.01	0.05	The babies of some pregnant women who drink water containing vanadium in excess of the action level may have an increased risk of developmental effects, based on studies in laboratory animals.

Table 6 - DETECTION OF FEDERAL DISINFECTANT/DISINFECTANT BYPRODUCT RULE

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL (MRDL)	PHG (MCLG)	Typical Sources of Contaminant
Total Trihalomethanes	(2014)	11.9	7.5 - 15.8	80	N/A	By-product of drinking water disinfection
(TTHMs) (ppb)						
Haloacetic Acids (five) (ppb)	(2014)	ND	ND - 1	60	N/A	By-product of drinking water disinfection

Additional General Information on Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the USEPA's Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. USEPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

Lead Specific Language for Community Water Systems: If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with the service lines and home plumbing. *City of Rio Vista* is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

Summary Information for Violation of a MCL, MRDL, AL, TT, or Monitoring and Reporting Requirement

About our Arsenic: Some people who drink water containing arsenic in excess of the MCL over many years could experience skin damage or problems with their circulatory system, and may have an increased risk of getting cancer.

About our Iron: Iron was found at levels that exceed the secondary MCL. The Iron MCL was set to protect you against unpleasant aesthetic affects such as color, taste, odor and the staining of plumbing fixtures (e.g., tubs and sinks), and clothing while washing. Violating this MCL does not pose a risk to public health.

About our Manganese: Manganese was found at levels that exceed the secondary MCL. The Manganese MCL was set to protect you against unpleasant aesthetic affects such as color, taste, odor and the staining of plumbing fixtures (e.g., tubs and sinks), and clothing while washing. Violating this MCL does not pose a risk to public health.

2014 Consumer Confidence Report

Drinking Water Assessment Information

Assessment Information

A source water assessment was conducted for the WELL 07, WELL 09, and WELL 11 of the CITY OF RIO VISTA water system in December, 2002. According to the Drinking Water Source Assessment and Protection Program's Source Water Assessments Public Access web page, the Public Water Sources WELL 13, WELL 14, and WELL 15 of the CITY OF RIO VISTA water system number 4810004, do not have a completed Source Water Assessment on file. Booster Station - No completed TurboSWAP Assessment on file.

Well 07 - is considered most vulnerable to the following activities not associated with any detected contaminants:
Historic gas stations
Known Contaminant Plumes

Well 09 - is considered most vulnerable to the following activities not associated with any detected contaminants:

Sewer collection systems Wells

- Oil, Gas, Geothermal

Well 11 - is considered most vulnerable to the following activities not associated with any detected contaminants:

Golf courses

Housing - high density [>1 house/0.5 acres]

Wells - Water supply

Well 13 - No completed TurboSWAP Assessment on file.

Well 14 - No completed TurboSWAP Assessment on file.

Well 15 - No completed TurboSWAP Assessment on file.

Discussion of Vulnerability

All wells in the City of Rio Vista water system are currently on line. Assessment summaries are not available for some sources. This is because:

- The Assessment has not been completed. Contact the local Department of Health Services (DHS) Drinking Water field office or the water system to find out when the Assessment is scheduled to be done.
- The source is not active. It may be out of service, or new and not yet in service.
- The Assessment was not submitted electronically. The site used to obtain Assessments only provides access to Assessment summaries submitted electronically.

Acquiring Information

A copy of the complete assessment may be viewed at:

City of Rio Vista, Department of Public Works

One Main Street

Rio Vista, Ca 94571

You may request a summary of the assessment be sent to you by contacting:

Dave Melilli

Director of Public Works

(707) 374-6451, etc. 1116

For more info you may visit <http://swap.ice.ucdavis.edu/TSinfo/TSintro.asp> or contact the health department in the county to which the water system belongs.